

**CORRIGENDUM-II**

May 23, 2017

**Ref. Tender No. BGL/351/2017-18, Dated: 05.05.2017**

**Sub: Procurement of 4 Nos of 8500 SCMH Meter Regulating Skids (MRS) for supplying NG to Domestic Customers at Hyderabad, Vijayawada & Kakinada**

This is for general information to all bidders that following details enclosed herewith shall form part of the bidding documents.

This is for general information to all bidders:

Sr. No.	Doc ref	Page no./ Clause	Section / Bid Document Description	Bidder's Queries	BGL REPLY
<b>TECHNICAL QUERIES</b>					
1	Vol II of II	43 of 43	SOR Item Description 1.0	Clarification regarding RFD meter sizing/CLGS	Enclosed Revised SOR with change in description as Annexure-I.

**Bidder shall take in to account the above while submitting their bid.**

**The Corrigendum – II shall form the integral part of the tender document.**

**All other Terms and Conditions of the tender document shall remain unaltered.**

**M/s. Bhagyanagar Gas Limited**

**Bonny K Joseph**  
**Dy. Manager (C&P)**

**Procurement of 4 Nos of 8500 SCMH Meter Regulating Skids (MRS) for supplying NG to Domestic Customers at Hyderabad, Vijayawada & Kakinada (Tender No. BGL/351/2017-18, Dated: 05.05.2017)**

**PROCUREMENT OF METER REGULATING SKID (MRS) – SOR – REVISED**

S. No	Locatio	Description	Qty	Basic Rate (Rs)	per unit Excise Duty (Rs)	per unit sales tax without "C" Form (Rs)	per unit freight upto project site by Road including transit insurance & all other taxes like octroi, entry tax etc (Rs)	Service Tax Applicable on Freight charges(on column 8) (Rs)	Per Unit FOT site (Rs)	Total Cost on FOT Basis (Rs)
1	2	3	4	5	6	7	8	9	10	11
1.0		Supply and Commissioning of Dual Stream Metered Regulating Station (MRS) Skid with 4" inlet and 6" outlet; for inlet pressure range 15 to 26 (g) & outlet pressure of 4 Barg. (g) having 8500 SCMH Capacity for each filtration & PRS stream & with dual RPD meters after filtration, one of 4" G400, 300# for 150 to 8500 SCMH & other of 2" G65, 300# for 20 to 1250 SCMH capacity. RPD Meter's shall be with Battery operated EVC having integral/external GPRS and GSM Battery operated Modem, Software's, Cables between EVC & Modem, local communication / configuration cable for EVC to Laptop, external Power supply to be provided for Modem and EVC with suitable power supply unit for 230 VAC input. Modem for Host computer, cables, drivers, software, complete in all respects as per P&ID and other technical details of tender.			-----% %	-----% %			(5+6+7+8+9)	(4*10)
1.1	Hyderabad	MRS Skid as per above requirement	02							
1.2	Vijayawada	MRS Skid as per above requirement	01							
1.3	Kakinada	MRS Skid as per above requirement	01							

**Note:**

- The Quoted Rates should include the Third Party Inspection Charges.
- Only BGL approved Third Party Inspection Agencies are to be deployed.
- The Rates should be in INR only.
- Supplier shall provide one set of Mandatory Spares with among three Skids and price shall be included in the quote rate.

