

**CORRIGENDUM-I**

May 29, 2017


**Ref. Tender No.BGL/354/2017-18, Dated: 19.05.2017**

**Sub: Procurement of 5000 SCMH Compact DRS suitable for underground installation to supply NG to Domestic Customers at Hyderabad and Vijayawada.**


**This is for general information to all bidders that following details enclosed herewith shall form part of the bidding documents.**

**This is for general information to all bidders:**

Sr No	Section No.	Page No.	Clause No	Subject	Bidders Queries	Buyer Reply
<b>TECHNICAL QUERIES</b>						
1	VOL II OF II	12 of 39	9.0	<b>QUALITY ASSURANCE / QUALITY CONTROL:</b> The Contractor shall prepare a detailed quality assurance plan for the execution of Contract for various facilities, which will be mutually discussed and agreed to.	Bidder raised query that for complete DRS, Bidder's QAP will be submitted during bidding which will be mutually agreed during detail engg.	Accepted
2	VOL II OF II	8 of 39	2.0	Scope of Supply: Inlet Pressure: 19 K/cm2	Bidder requested BGL to kindly furnish process parameters in order to design DRS.	<b>Design &amp; operating data:</b> Inlet Pressure: 10-19 K/cm2 Outlet Pressure : 4 K/cm2



			Outlet Pressure : 4 Kg/cm <sup>2</sup>		
	VOL II OF II	20 of 39	Section 10 - 2.0	Design & operating data: Inlet Pressure: 10-16 Barg Outlet Pressure : 4 Barg	
	VOL II OF II	26 of 39	Section 10 - 2.0	Design & operating data: Inlet Pressure: 19-26 Barg Outlet Pressure : 4 Barg	
	VOL II OF II	35 of 39	P&ID	Design & operating data: Inlet Pressure: 10-18 K/cm <sup>2</sup> Outlet Pressure : 4 K/cm <sup>2</sup>	
3			P&ID	Skid Line Size	Confirm the skid line size before filter is 4" and after PRS is 4" as per the &ID and whether it is needed to follow line size as mentioned in &ID.
4				Inlet Pressure Rating	As per P&ID maximum Inlet pressure is 19 Bar and inlet rating is shown as #150RF where as in process parameter you have mentioned inlet pressure as 19-26 bar at one place and 10-16 bar at another place. Bidder requested the need of #300 Rating or #150 Rating skid and to provide the min & max inlet pressure as asked in query no 2.
5	VOL II OF II	21 of 39	Scope of work 4.2.iii	Turbine meter with GSM for meter reading to be provided	Bidder requested to confirm that there is no requirement of Meter, EVC & GSM for this tender.
6	VOL II OF II	21 of 39	Scope of work 4.2.iv	Regulator is direct acting	Since the flow rate is very high and 2.5% accuracy class is mandatory, then it shall be achieved only through pilot operated pressure regulator. Bidder requested to confirm the required regulator shall be PILOT OPERATED type.
					<b>tender conditions prevails</b>



7	VOL II OF II	36 to 37 of 39		Vendor List	Nirmal make Filter/ Pressure relief valves/ safety relief valves supplied to many Gas companies like Gujrat Gas, GAIL including BGL & installed at many CGD stations, therefore we request you to accept Nirmal make safety relief valves/ Filter We will submit the PO copy of the PSV supplied to GAIL /other CGD companies along with our bid documents. Please confirm its acceptance.	<b>Please read the last sentence of vendor list in Bought out items page.</b>
8	VOL II OF II			Inspection & Testing	Third party inspection is applicable for DRS & scope of TPPIA shall be vendor's scope. Bidder requested to nominate TPPIA.	<b>PNGRB approved TPPIA is required</b>
<b>COMMERCIAL QUERIES</b>						
1	VOL I OF II	2 fo 86		Bid Due Date	Bidder requested to provide the 10 days time for bid submission after receipt of pre bid queries reply.	<b>tender conditions prevails</b>
2	VOL II OF II	11 of 39	Section-8, SCC, Clause 6.0 (b)	Balance 10% payment term after no claim certificate & commissioning.	Bidder requested to make the necessary changes in payment term for balance 10% against commissioning or within 45 days from date of dispatch whichever is earlier. In case if commissioning is not happened within 45 days, you are requested to release the balance 10% payment of the supplier. As bidder have being MSMED, as per Govt regulations, all payment/dues shall be cleared within 90 days form date of dispatch. This clause shall be regularly followed by all CGD as well as govt entities.	<p>Clause No.6 (b) :Terms of Payments shall be read as</p> <p>b)10% payment shall be released after submission following documents: i) No Claim Certificate. ii) Final acceptance of material by BGL. iii) After successful commissioning of MRS</p> <p><b>TO BE READ AS</b></p> <p>Clause No.6 (b) :Terms of Payments shall be read as (b)10% payment shall be released after submission following documents:</p> <p>i) No Claim Certificate.</p> <p>ii) Final acceptance of material by BGL. iii) After successful commissioning of MRS.</p> <p><b>However, in case of delay in the commissioning of the items supplied by party or there of beyond 6 months from the date of supply at site, the balance payment shall be released to the party withholding PRS, if applicable.</b></p>



Bidder shall take in to account the above while submitting their bid.

The Corrigendum – I shall form the integral part of the tender document.

All other Terms and Conditions of the tender document shall remain unaltered.

M/s. Bhagyanagar Gas Limited

Bonny K Joseph  
Dy. Manager (G&P)

