

CLARIFICATION-I

29.10.2011

Ref: Tender No. BGL/163/2011-12 dtd 14.10.2011.

Sub: Tender for Procurement of UPS for CNG Stations in Hyderabad & Vijayawada.

This is for general information to all bidders that the following changes shall form part of the tender document.

| S. No | Description | As per Tender Document | To be Read as |
|-------|---|---|--|
| 1 | Volume II of II, Section 11, "Technical Specifications", Page 20 of 27, S. No 14: | Back up time for UPS must be 2 hours on full load : 2 Hours | Back up time for UPS must be 1 hour on full load: 1 Hour |

Replies to bidders queries are enclosed at *Annexure - I*.

Bidder shall take in to account the above while submitting their bid.

The Clarification -I shall form integral part of the tender document.

All other Terms and Conditions of the tender document shall remain unaltered

For and on Behalf of Bhagyanagar Gas Limited



A.V.V.R. Murthy
Manager (C&P)


Manager (Contracts & Procurement)
BHAGYANAGAR GAS LTD.
2nd Floor, Parishram Bhavan
Basheerbagh, Hyderabad - 500 004

Enclosure:

1. Annexure - I: Replies to Bidders Queries.

Replies to Bidders Queries**Annexure - I**

| S. No | Bidders Query | Reply to Query |
|--------------|--|---|
| 1 | For 2 KVA & 3 KVA Online UPS Manual Bypass facility is not available & Automatic Bypass facility is available. | Tender Condition Prevails. |
| 2 | For 2 KVA & 3 KVA Online UPS Protection cost is extra. | Bidder has to load all cost of UPS including protection cost etc, if any as per the technical specifications as mentioned in the tender and has to quote accordingly. |
| 3 | Is there any tender document cost separately? | Tender document fee is not applicable for this tender. |


Manager (Contracts & Procurement)
BHAGYANAGAR GAS LTD.
2nd Floor, Parishram Bhavan
Basheerbagh, Hyderabad - 500 004