

Ref. Tender No. BGL/540/2021-22, dated 28.03.2022

Sub: Tender for Hiring Contract Service for Hydro Pressure Testing, Refilling and Painting of CO2, Flooding Cylinders and DCP Modular Fire Extinguishers at all three GA locations.

Replies to Pre- Bid Queries/ Addendum-01

Sl.no	Vol & Section	Page no	Clause / Description	Bidder Queries	BGL Remarks / Clarifications
1	Vol I of I, Section-5, Scope of Work	68 to 71	General	Bidder requested to confirm if, all cylinders are to be collected at one time or only one cylinder at a time (The transportation cost will be quoted accordingly).	The vendor shall collect only one cylinder at a time.
2	Vol I of I, Section-5, Scope of Work	68 to 71	General	Bidder requested to confirm who will be responsible for dismantling the cylinders from their existing location.	The contractor shall appoint authorized personnel for dismantling and installing the CO2 Flooding System.
3	Vol I of I, Section-5, Scope of Work	68 to 71	General	Bidder requested to confirm if vendor is responsible only for the servicing of the cylinders. Will the servicing of the manifold be carried out by BGL.	Vendor is responsible only for the servicing of the cylinders.
4	Vol I of I, Section-5, Scope of Work	68 to 71	General	In case of valve failure, Supply of New Valves will take a minimum of 10 working days.	Whenever there is valve failure during inspection/testing the contractor shall obtain permission from Site-In-charge to replace with new valve and deliver within the contract period.
5	Vol I of I, Section-5, Scope of Work	68 to 71	General	Bidder requested to send photographs/drawings of the existing valves so that prior arrangement can be made for procuring new ones.	Site visit can be done to view the existing valves of Flooding systems installed at respective locations.